CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0694:255 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Fire Control Instruments, 269 Grove Street, Newton MA 02166

Contact: Anthony Shalna (781) 471-3000 Fax (781) 471-3099

DESIGN: Model MMI-6S six zone interface module. Refer to listee's data sheet for detailed product

description and operational considerations.

RATING: 15-32 VDC, Power Limited, Supervised

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as control unit accessories for use with separately listed compatible fire alarm control

units.

2-04-2003 JEW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: FEBRUARY 4, 2003 Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager